

The views expressed in this note are informal and do not necessarily reflect the UK government's official policies.

1 Report

2 A techno-economic and financial analysis of 3 a Gulf-India undersea electricity 4 interconnector

5 **Abhishek Shivakumar¹, Lucas Kruitwagen², Miles Weinstein¹, Sebastian
6 Spiteri¹, Christopher Arderne¹, Youssef Almulla³, William Usher³, Mark
7 Howells^{4,5}, and Adam Hawkes⁵**

8 ¹ Climate Compatible Growth

9 ² Oxford University

10 ³ KTH Royal Institute of Technology

11 ⁴ Loughborough University

12 ⁵ Imperial College London

13 **Abstract:** As part of efforts to decarbonise, power systems around the world will need to cope with
14 increasing shares of intermittent renewable generation from technologies such as wind and solar
15 photovoltaics (PV) in the coming decades. One promising solution to this challenge is cross-border
16 electricity interconnectors. This study is an independent combined techno-economic and financial
17 analysis of an electricity interconnector between Gulf Cooperation Council (GCC) countries and
18 India. A techno-economic model of a combined India-GCC power system was developed using
19 OSeMOSYS, an open-source energy system modelling tool and combined with a financial model.
20 The models were applied across 75 scenarios covering a range of cost variables and solar PV
21 locations in the GCC. We find that a techno-economic case for a GCC-India interconnector is clear:
22 an interconnector is part of the least-cost 'optimal' power system in 64 of the 75 scenarios studied.
23 The trend of electricity flows gradually shifts from the India->GCC direction in 2030 to the other
24 way around by 2050. The overall trade volumes are influenced by the location of the solar PV farm;
25 locations further to the west contribute towards higher trade volumes in the GCC->India direction.
26 Of the cost variables considered in the study the overall (social) discount rate is most strongly
27 correlated with the interconnector trade volumes. The financial case for the CCG-India
28 interconnector is less clear. Of the projections developed for the scenarios from the technoeconomic
29 model, only a small number are immediately investible. It is also expected that a smaller
30 interconnector will be a more attractive investment opportunity, for a trade-off in total system cost
31 reductions.

32 **Keywords:** energy systems modelling; techno-economic analysis; financial modelling; electricity
33 interconnectors; India; Gulf Cooperation Council;

34		
35	Introduction	2
36	Modelling approach	2
37	Model setup	3
38	Scenario Parameterisation	3
39	Counterfactual Analysis	5
40	Business Model Selection	6
41	Interconnector Capital Structure	7
42	Cost of Capital	8
43	Cashflow Analysis	8
44	Risk Analysis	9
45	Results	9
46	Impact of solar PV location and cost variables	10

47	Cross-border electricity trade flows through the GUI	12
48	Impact on power capacity expansion in India	14
49	Financial Feasibility	15
50	Risk Sensitivity	16
51	Conclusions	17
52	Author contributions	17
53	Funding	18
54	Acknowledgements	18
55	Disclaimer	18
56	References	18
57	Appendices	19
58	Appendix A: Model structure	19
59	Appendix B: Scenario table	20
60	Appendix C: Risk Sensitivity	21
61		

62 Introduction

63 Many large economies have now announced net zero target years. These include the UK
 64 (The Government of the United Kingdom, 2020), EU, and China (Varro and Fengquan,
 65 2020). With President Biden now in office, the US is also expected to announce a net
 66 zero target imminently¹. The IEA recently suggested that a net zero target for the global
 67 energy system is now within reach (Fatih Birol, 2021). While India has not yet
 68 announced a net zero target of its own, it is emerging as a global leader in renewables
 69 deployment - ranked 3rd and 4th globally in solar photovoltaic (PV) and wind power
 70 capacity additions in 2019 (REN21, 2020). The power sector will therefore have to cope
 71 both with increasingly electrified energy systems as well as higher shares of intermittent
 72 renewable generation capacity such as wind and solar photovoltaics (PV) in the coming
 73 decades. One promising solution to this challenge is cross-border electricity
 74 interconnectors. By connecting geographically distributed renewable potentials to
 75 electricity demands across borders, supply-demand mismatches (Brinkerink et al.,
 76 2019). Championing this concept, India's Prime Minister has announced the ambitious
 77 'One Sun, One World, One Grid' initiative that envisions a globally interconnected
 78 electricity grid to complement the plans of the International Solar Alliance (ISA)² for
 79 round-the-clock solar power generation. The objective in the first of three phases in this
 80 initiative is to assess the technically and financially viability of an interconnector between
 81 the six Gulf Cooperation Council states, India, and South-East Asia.

82 This study is an independent combined techno-economic and financial analysis of an
 83 electricity interconnector between GCC and India. It aims to answer four key questions
 84 in this regard:

- 85 • Is an electricity interconnector between GCC and India considering techno-
 86 economically and financially favourable across a range of scenarios?
- 87 • If built, what are the daily and seasonal patterns of trade flows across the
 88 interconnector?
- 89 • What are the key factors that influence the choice to build and profile of
 90 electricity flows across the interconnector?
- 91 • How can a GCC-India interconnector contribute towards India's transition to a
 92 low or zero emissions power system?

93 Modelling approach

94 Several recent studies of India's long-term energy outlook - such as those by NREL
 95 (Rose et al., 2020) and TERI (Spencer et al., 2020) - are underpinned by techno-
 96 economic models. Similarly, the modelling tool used to carry out the techno-economic
 97 analysis in this study is OSeMOSYS (Howells et al., 2011), a widely used open-source

¹ Not yet formalised

² <https://isolaralliance.org/>

energy planning tool. OSeMOSYS uses linear optimisation to identify the least cost 'optimal' system over a given time horizon under user-specified constraints.

A financial model has been prepared alongside the technoeconomic model, capable of taking the technoeconomic model's projections of the energy system as inputs, and determining whether the interconnector would be investible beyond being technoeconomically desirable. The financial model is implemented as both a spreadsheet and a Python module.

Model setup

The techno-economic model was developed in two phases. In phase 1, the model included a representation both GCC and Indian power systems. It consisted of six countries on the GCC side, with Saudi Arabia divided into four regions and the remaining five countries each represented separately. The Indian power system was divided into five regional grids. Further, an interconnector between Oman on the GCC side and the Western grid of India is also represented.

The model was then updated based on the feedback from phase 1 to include bi-directional trade, the option of multiple solar PV sites in the GCC, and battery storage deployment in India.

The financial model has been designed to extend the findings of the technoeconomic model, drawing on a common group of scenarios, and extending the findings with further financially-relevant parameters and assumptions.

Scenario Parameterisation

The development of the technoeconomic and financial models has been closely linked - the ranges of key parameters for both models was decided between the modelling teams prior to the scenarios being run. In this Phase 2 of the GUI feasibility study, scenario parameterisation has focused closely on the costs of the interconnector, which Phase 1 showed to be determining factors in the interconnector's desirability. These parameters include capital costs, operating costs, the social discount rate, and the project cost of capital.

We obtain figures for capital expenditure (CAPEX) by other similar HVDC interconnector projects. Based on these projects, we are able to significantly reduce the parameter search space. Table 1 shows key CAPEX parameters for comparator projects. We choose a CAPEX parameter range of \$0.45mn/MW to \$2.0mn/MW, which captures the range of comparable overland and underwater interconnector projects.

Table 1: Interconnector capital cost comparison

Interconnector	Size [MW]	Distance	Over/under	Cost		Sources*
				[US\$m]	[US\$m/MW]	
ES-FR	2000	70	overland	837	0.42	1
Labrador Island Link	900	1100	overland	2145	2.38	2
CASA-1000	1300	1227	overland	977	0.75	3
GCCIA	1200	1104	overland	1537	1.28	3
PowerLinks	3000	1200	overland	341	0.11	4
Plains & Eastern	4000	1160	overland	2500	0.63	5
IL/Cyprus/GR	2000	1500	underwater	900	0.45	6
Viking Link DK-GB	1400	765	underwater	2390	1.71	7
English Channel FR-GB	2000	40	underwater	412	0.21	8
Maritime Link (CA)	500	180	underwater	962	1.92	9
Trans Bay Cable Project	400	85	underwater	440	1.10	10
Cross Sound Cable	330	39	underwater	120	0.36	11
East-West (IE-GB)	500	260	underwater	720	1.44	3
NorNed	700	580	underwater	720	1.03	3

Hudson Transmission Project	660	12	underwater	850	1.29	12
			MIN	0.11		
			MAX	2.38		
			MEAN	1.01		

*sources: 1: <https://web.archive.org/web/20111005233257/http://social.csptoday.com/ga/spain-invest-heavily-transmission-grid-upgrades-over-next-five-years>; 2: <https://www.transmissionhub.com/articles/transprojects/labrador-island-link>; 3: <https://sari-energy.org/wp-content/uploads/2019/07/Session-3-Case-Studies-on-Financing-Models.pdf>; 4: <https://documents.worldbank.org/en/publication/documents-reports/documentdetail/671171468017990099/estimating-employment-effects-of-powerlinks-transmission-limited-project-in-india-and-bhutan>; 5: <https://www.eia.gov/analysis/studies/electricity/hvdctransmission/pdf/transmission.pdf>; 6: <https://www.reuters.com/article/idUSKBN2B015M>; 7: <http://viking-link.com/>; 8: https://en.wikipedia.org/wiki/High-voltage_direct_current; 9: <https://www.linxon.com/project/maritime-link-emera-500-mw-hvdc-connection-project-canada/>; 10: https://en.wikipedia.org/wiki/Trans_Bay_Cable; 11: https://en.wikipedia.org/wiki/Cross_Sound_Cable; 12: <https://www.eia.gov/analysis/studies/electricity/hvdctransmission/pdf/transmission.pdf>

Operational expenditures (OPEX) were assumed to be negligible in Phase 1. In Phase 2 we return to this assumption and obtain OPEX rates for comparable submarine HVDC projects in the North Sea (Flament et al. 2014). Cables have a higher OPEX rate than converter station equipment, so we choose an OPEX range that represents a blend of these rates. This blend sufficiently covers the parameter space so that more detail can be added in downstream analysis.

While the ultimate discount rate used for the project will be a function of the capital structure of the project, a range is chosen to be represented in the technoeconomic modelling of the project. The financial model can then be tuned to different scenario runs for consistency between the two models. With further research we have been able to narrow the range of discount rates as compared to Phase 1.

The World Bank (Meier, P. 2020) has issued guidance on the use of discount rates in the analysis of electricity projects. Taking a welfare approach, they adopt social discount rates in the range of 5% to 10%. This range is used as the social discount rate in the technoeconomic model.

The project discount rate will be determined by the cost of capital of those who fund the project. In the financing of the GCCIA Interconnector, for example, costs were split according to which parties most benefited from the interconnector, and a commensurate cost of capital (7.55%) was used for the project. For this project, costs of capital are expected to also fall in this range. The range of 5% to 10% is likewise used for the project cost of capital.

With the input parameter spaces established, the scenarios can be sampled from their range. The range for each variable is shown in **Table 2**. Using these input data ranges, twenty-five 'samples' were created to combine different values for each parameter through a process of Latin Hypercube sampling.

Table 2. Cost input data ranges to create twenty-five 'samples'

Variable	CapitalCost	DiscountRate
Interconnector CAPEX	450 \$/kW	2000 \$/kW
Interconnector OPEX (% of CAPEX)	1.2%	2.1%
Social discount rate	5%	10%
Project cost of capital	5%	10%

In addition to the twenty-five samples, three potential sites for a solar PV farm in the GCC were also identified. The sites were selected based on their longitude and solar PV generation potential. The selected locations, and their coordinates, are East (17.4599 N, 54.8877 E), Centre (22.2344 N, 42.8657 E), and West (29.0957 N, 35.5765 E). The first site is located in Oman while the remaining two are in Saudi Arabia.




Figure 1. Average daily solar PV profile by location. X-axis: Hours in UTC; Colour bar: Capacity factor in % by hour for each solar PV site. Values for the five locations in India are averages of the existing solar PV installations in each region. For GCC, the profiles are specific to selected sites for a potential solar PV farm feeding the GUI

The time difference between the GCC and India, especially relating to coincident solar power generation in the former and peak demand hours in the latter, is a key factor in considering the GUI. In order to analyse the importance of this time difference, three potential sites for a solar PV farm are selected and included in the techno-economic model. Each site is considered independently of the other – only one site is active in each scenario. The three sites are each analysed across the 25 samples described in the previous section to provide a set of 75 scenario runs.

Counterfactual Analysis

A key criterion in the design of the financing of an interconnector project is understanding which of the interconnected parties has the most to gain from the interconnection. The benefitting party is more likely to finance the interconnector and therefore the capital structure and costs of capital is dependent on who the interconnector beneficiary is.

Determining the interconnector beneficiary is not trivial. Interconnected countries experience a range of benefits including reduced system marginal costs, reduced system capital costs, access to markets, and stability of electricity supply (SARI/EI/IRADE Team 2019). These benefits may be asymmetrically distributed and difficult to quantify. They also depend on the choice of counterfactual scenario. A counterfactual scenario with a hard decarbonisation constraint, for example, will have a different distribution of marginal and capital costs than a business-as-usual baseline.

To develop some initial insight into the distribution of benefits of the proposed interconnector, we compare a counterfactual business-as-usual case that has been constrained to not build the interconnector to an unconstrained central scenario. **Figure 2** shows that the addition of the interconnector has a large impact on the mean marginal cost of electricity in interconnected countries, weighted by hourly electricity demand. The interconnector reduces mean electricity costs in GCC countries. These savings may or may not be forwarded to rate payers depending on the design of the electricity market.





Figure 2: Marginal electricity costs in counterfactual scenario by country

Figure 3 shows that the presence of the interconnector decreases total system costs in GCC countries, while total system costs in India are largely unchanged. This is consistent with the findings of the techno-economic model that show that most interconnector trade volume occurs in the direction of electricity export from India to the GCC.



AE: United Arab Emirates; **BH:** Bahrain; **GC:** GCC; **IN:** India; **KW:** Kuwait; **OM:** Oman; **QA:** Qatar; **SA:** Saudi Arabia

Figure 3: Total system costs in counterfactual scenario by country

Despite the finding of reduced marginal and system costs in GCC countries, it remains unclear which country or collection of countries will have the most incentive to pay for the interconnector. Interconnectors are often built to give national champion industries access to export markets, such as the Ireland-UK interconnector built by the Ireland grid operator to give zero-marginal-cost Irish wind power access to the UK power market (SARI/EI/IRADE Team 2019). Considering that this project is of national interest to the Government of India under the One Sun, One World, One Grid concept, geopolitical interests may prove the determinant of which party builds the interconnector.

In the financial model, we proceed with the assumption that the interconnector will be championed by the Government of India, built by Indian companies, and financed by development and investment banks operating in India.

Business Model Selection

The business models of the proposed interconnector describe how it will make revenue to cover its costs and service its debt. Four business models have been identified which can provide cost recovery for the proposed interconnector.

1. Generator Supply Dedicated Line - For a unidirectional line from a generating station to a demand node, costs are recovered directly from the sale of electricity. Typical of, e.g., remote hydro power resources.
2. Regulated grid tariff - A regulated tariff for transmission capacity, levied by the regulator. A typical arrangement for, e.g., domestic transmission lines. Tariffs may be levied on generators or consumers.
3. Transmission rights model - Retailers buy forward transmission rights which have fixed prices. Typical for well-coupled markets, e.g., France-UK.
4. Congestion charge model - Interconnector levies a variable 'congestion' charge. Most common between markets where variable arbitrage opportunities occur, e.g., between wind-rich Ireland and the UK.

Because two-way trading is desired for the CCG-GUI project, consistent with the One-sun-one-world-one-grid concept, a generator-supply business model is not appropriate for the financial model. The least-costs decision-making of the technoeconomic model takes full advantage of time-of-use marginal costs, so the financial model must also reflect the significant and variable arbitrage opportunities expected to exist between the GCC and Indian power markets. As such the design of the financial model proceeds assuming a variable time-of-use tariff consistent with a congestion charge model. This tariff will be determined by the technoeconomic model and will be based upon the difference between the marginal costs of electricity in India and the GCC.

Interconnector Capital Structure

Models for financing large electricity infrastructure projects include private finance, utility finance, and public-private partnership. These financing arrangements feature different typical capital structures for the legal entity that owns the interconnector. The capital structure of the entity will be used to determine the weighted average cost of capital (WACC) which will be used to interpolate the technoeconomic results. The capital structure also plays a crucial role in the cashflow of the interconnector project, determining interest payments and financing fees.

For a project of this size, a public-private partnership is typical, where governments, regulated companies, private lenders, and multilateral financial institutions jointly finance the infrastructure. This implies a capital structure that combines private and public (government) equity, commercial debt, concessionary loans, and public grants. Concessionary loans would typically be provided by a multilateral development bank.

We prepare a baseline capital structure which can be adjusted according to different assumptions. This capital structure is comparable to other large interconnector projects, such as the PowerLinks interconnector that carries electricity from Bhutan to New Delhi, India (PowerLinks Transmission Ltd 2009). summarises the GUI baseline capital structure and compares it to the PowerLinks capital structure.

Table 3: GUI baseline capital structure and comparison project

GUI Baseline		PowerLinks Transmission Ltd	
Grant	[Unspecified] 2.5%	[None]	0%
Equity	[Unspecified] 22.5%	Tata Power Company Ltd	12.9%
		Powergrid Corporation of India Ltd	12.4%
Sum 25%		Sum 24.3%	
Debt	Development Bank 1 16.5%	International Finance Corporation (World Bank)	22.5%
	Development Bank 2 19.5%	Asia Development Bank	19.9%
	Commercial Bank 22.5%	Infrastructure Development Finance Limited	17.1%
	Government Debt 16.5%	State Bank of India	15.2%
Sum 75%		Sum 74.7%	
Sum	100%		100%

271 **Cost of Capital**

272 With a capital structure in place, we can begin to develop assumptions for the GUI's cost
273 of capital. We obtain literature values to provide preliminary assumptions for the cost of
274 equity and the cost of debt of the project.

275 The World Bank occasionally publishes a schedule of lending rates and fees that can be
276 used to estimate the debt margin and fees levied for World Bank lending (The World
277 Bank 2021). For India, World Bank variable spread lending is available at 0.82% for a
278 15-year tenor. Keeping with the analogous comparison to the PowerLinks
279 interconnector, we also obtain a similar debt margin for the Asia Development Bank
280 (2021).

281 For commercial and government debt, the rates are more difficult to obtain. We use a
282 rate of 7% for government lending, slightly more than the risk-free rate for India
283 (countryeconomy.com 2021). For commercial lending, our baseline rate is 20%.

284 We develop a cost of equity using the capital asset pricing model. In this case we include
285 only the risk-free rate and the equity market risk premium. We assume the risk-free
286 rate to be equal to the yield of a Government of India sovereign bond: 6.15% (ibid.).
287 We use an equity risk premium of 7%, following the recent guidance of RBSA Advisors
288 (2020).

289 Variable spread lending applies debt margins on top of a baseline interest rate, typically
290 the London Interbank Overnight Rate (LIBOR). We use a baseline LIBOR of 0.2%
291 (bankrate.com 2021).

292 **Cashflow Analysis**

293 With a cost of capital and capital structure decided, the full cashflow of the proposed
294 GUI can be projected. A key difference between the logic of the technoeconomic model
295 and the financial model is that in the technoeconomic model, construction costs are
296 assumed to be overnight in a given year. In the financial model, we recognise that for
297 a construction project of this size, project costs begin several years before the nominal
298 commissioning year. The financial model spreads construction costs over the five years
299 preceding each capacity addition using a fixed spending profile.

300 Construction costs are met first by grant and equity drawdowns. Once equity and grant
301 allocations are depleted, debt is drawn down to pay construction costs. Each capacity
302 addition is considered a new project phase, so equity can be drawn down for distant
303 future phases, while debt is being drawn down for near future phases where equity
304 funding has been depleted, all while debt for previous construction phases is being
305 serviced.

306 Debt drawdowns occurring prior to debt servicing will incur interest payments during the
307 construction period. A commitment fee is also levied on debt which has been committed
308 but not drawn down prior to the commencement of payments (The World Bank 2021).
309 An upfront fee is charged based on total debt requirement when construction begins
310 (Ibid.). These fees and interest payments all increase the total costs and the size of the
311 loans required.

312 Operating expenses are determined as a portion of the total installed capital asset value.
313 The capital asset value is equal to the unit construction costs multiplied by the installed
314 capacity. In this way, operating expenses scale with the amount of installed capacity
315 and do not extend beyond the equipment's economic lifespan. Following the North Sea
316 Grid annexes, operating expenses are estimated to be in the range of 1.2% to 2% of
317 capital asset value (Flament et al. 2015).

318 Operating revenue is determined by the technoeconomic model. We assume that the
319 interconnector's variable tariff captures the full price arbitrage between the GCC
320 interconnection node and the Western India grid node. Trade volumes are determined
321 by the technoeconomic model. Revenue is taxed with a fixed corporate tax rate which
322 we set at 15% as a baseline. For a project this large, the corporate rate would be subject
323 to negotiation directly with the government.

324 Debt is serviced with fixed annual payments. We adopt a baseline loan tenor of 15 years,
325 fitting the 25-year economic lifespan of the infrastructure. The financial model time
326 horizon therefore extends to 2075, 25 years beyond the end of the technoeconomic

327 model, wherein 2049 is the last available year for an overnight capacity addition. Each
328 overnight capacity addition is retired after its 25-year economic life with no terminal
329 value.

330 A dividend is paid to the interconnector's shareholders from the cashflow available to
331 equity. The net present value of the project is calculated using the remaining net
332 cashflow discounted at the calculated weighted average cost of capital (WACC). Other
333 key financial metrics for the project include the equity internal rate of return (Equity
334 IRR) and project internal rate of return (Project IRR). The Project IRR is the IRR for the
335 'unlevered' project. The Equity IRR represents the IRR for the full 'levered' project. The
336 Project IRR is used to evaluate returns to the project; the Equity IRR is used to evaluate
337 returns to the project investor. We use the 'modified' IRR (MIRR) method, which is
338 always calculable and makes more sound assumptions concerning reinvestment
339 opportunities. The MIRR is also more suitable for multiphase projects with complex
340 cashflows.

341 Risk Analysis

342 The sources of uncertainty and risk to a project of this nature can be classified under
343 financial, commercial, and economic risk. Financial risks include interest rate risk,
344 currency risk, and commodity risks. Commercial risks include offtake risk, non-
345 performance risk, construction risk, environmental risk, and security risks. Economic
346 risks include those related to the macroeconomy and drivers of demand.

347 These risks can be mapped to parameters in the financial model. While this mapping is
348 imperfect, it allows model results to be stress-tested for robustness. **Table 4**
349 summarises project risks and their analogous parameters in the financial model which
350 can be impaired and stress-tested.

351 **Table 4:** Project risks and sensitivity testing in the financial model
352

Risk	Description	Financial Model Parameter
Financial Risks		
Interest Rate	Risk that variable rate loans will suffer rate increases	Stress test by increasing LIBOR
Current	Risk that currency valuation/devaluations will increase the project costs or decrease revenues in real terms	Potentially transferred as currency hedging. Stress test by increasing opex for option cover.
Commodity	Risk that covarying or substitute commodity prices will change averse to project economics	Included in technoeconomic scenario ensemble
Commercial Risks		
Offtake	Unanticipated reduced demand for interconnection services due to offtake failure	Stress test by reducing revenue
Non-performance	The interconnector may suffer unanticipated downtimes or failures	Stress test by reducing revenue
Construction	Construction can suffer delays or cost overruns	Stress test by increasing construction costs beyond 100%
Environmental	Operating and financial impairment due to acute and chronic environmental risks	Potentially transferred as additional insurance, imposing additional opex
Security	Operating and financial impairment due to acute and chronic security risks	Potentially transferred as additional insurance imposing additional opex
Economic Risks		
Macroeconomic	Unanticipated reduced demand for interconnection services due to macroeconomic downturn	Stress test by reducing revenue


353 Results

354 The results of the techno-economic modelling are divided into three parts. First, we
355 analyse whether or not the GUI is considered a techno-economically favourable across
356 the 75 scenarios studied. As part of this, we also identify the seasonal and daily patterns
357 of trade flows through the GUI. We then assess the impact of cost variables (**Table 2**)

358 and solar PV farm location on the GCC side on the volume of bi-directional trade through
 359 the GUI in the cases where it is built. Finally, we explore the potential contribution of
 360 the GUI to India’s transition to a low or zero carbon power system. In this third part, we
 361 contrast the role of the GUI against battery storage located in India.


362 **Impact of solar PV location and cost variables**

363 The model results from 75 scenarios show a strong techno-economic favourability of the
 364 GUI. The GUI is a part of the least-cost, ‘optimal’ system in all 75 scenarios as shown in
 365 **Figure 4**. Of these 75 scenarios, the GUI is built to its maximum capacity of 25 GW in
 366 61 scenarios. The number of cases where the GUI is not built varies depending on the
 367 site of the solar PV farm, with the ‘West’ site considered most favourable.



368 **Figure 4. GUI capacity by scenario**

369 When built, the GUI can trade bi-directionally. **Figure 5** below compares the trade
 370 volumes in both directions across the GUI until 2050 over the 75 scenarios.



371 **Figure 5. Total bi-directional electricity trade volumes through the GUI between**
 372 **2028 and 2050**

373 The total trade flows in the India->GCC direction, in the 70,000-80,000 GWh range, are
 374 significantly higher for all cases as compared to that in the opposite direction, which are
 375 below 10,000 GWh for all cases. It appears that GUI flows in the India->GCC direction
 376 stem primarily from hydro-based generation in India, allowing the GCC to take
 377 advantage of low cost, low carbon electricity from the GUI. This is especially beneficial
 378 given that the UAE and Saudi Arabia - the two largest power systems in the GCC - both
 379 have emissions reduction targets implemented based on their respective NDCs
 380 (Kingdom of Saudi Arabia, 2015; United Arab Emirates, 2020).

381 In the India->GCC direction, trade flows generally increase as the potential solar PV
 382 farm location moves further east. Conversely, in the GCC->India direction, the total
 383 trade flows generally decrease from West to East. This trend signifies the importance of
 384 the location of solar PV farm site. The further West the site is located, the closer its
 385 generation will coincide with India's evening peak demand hours. However, there is a
 386 diversity of trade flows across the scenarios in each direction. The main contributing
 387 factor that correlates with the trend in trade volumes in the GCC-India direction is the
 388 discount rate of each case. At the same time, the discount rate is strongly correlated to
 389 the share of variable renewable energy (VRE) capacity in India. A higher discount rate
 390 leads to a lower share of VRE Both these trends are shown in **Figure 6**.




391 **Figure 6. Impact of social discount rate on trade volume**

392 The trend of higher discount rates leading to lower shares of VRE capacity - which have
 393 relatively high upfront costs but low running costs - is expected and has been reported
 394 in the literature (García-Gusano et al., 2016). In cases with lower shares of VRE
 395 capacity, the GUI provides a relatively low-cost alternative for electricity generation,
 396 leading to higher trade volumes.

397 **Cross-border electricity trade flows through the GUI**

398 The results of hourly bi-directional trade flows for the years 2030, 2040, and 2050 are
 399 shown in **Figure 7**. The direction of trade flows is dominated by electricity from India to
 400 GCC in 2030. This pattern remains consistent across all months and for most hours. The
 401 exceptions are between 14:00 – 16:00 UTC (19:30-21:30 IST) in all months outside
 402 India’s monsoon season. The time period coincides with the evening peak demand hours
 403 in India. During India’s monsoon season, the trade flow is entirely in the direction
 404 towards the GCC. This coincides with the likely availability of surplus hydropower
 405 generation in India.



406 **Figure 7. Hourly bi-directional trade volumes across the GUI in 2030, 2040, and**
 407 **2050**

408 Electricity flows through the GUI in 2040 see a continuation of the earlier pattern of
 409 India->GCC dominating the direction of trade. However, in addition to evening peak
 410 demand hours in India, there is increased flow of electricity from GCC->India during
 411 the daytime peak demand hours of 7:00 – 11:00 UTC (12:30 – 16:30 IST). Maximum hourly
 412 electricity flow in the GCC->India direction increases to just under 10 GWh while in the
 413 India-GCC direction it increases to 15 GWh.

By 2050 we see a reversal in the dominant direction of flow; electricity trade in the GCC->India direction now makes up a majority of total electricity trade volume. As India reaches its technical potential for renewable capacity expansion, electricity imports from the GUI represent a relatively low-cost alternative. While the seasonal pattern of trade flow from India->GCC remains, the flow in the opposite direction is consistently high throughout the year. The flow now bridges the daytime and evening peak hours, coinciding with both as well as the hours in between. Overall, the GUI is utilised extensively throughout its operational life across the 75 scenarios. The direction of utilisation varies between hours, months, and years.

Impact on power capacity expansion in India

The ensemble of 75 scenarios results in a range of capacity expansion pathways for India's power system (**Figure 8**). The total power generation capacity ranges between 1300 and 1600 GW. The mix of power generation technologies that comprise the system is consistent across the scenarios, with the capacities of hydro and nuclear power in the total capacity mix remaining constant. However, the scenarios are characterised by a wide range of wind and solar capacities from a combined total of 650 to 930 GW.





Figure 8. Power generation capacity mix in India by 2050, across twenty-five scenarios and three solar PV sites

Another technology that can help integrate VRE into the power system is electricity storage. Based on the characteristics of the technology they may be best suited for electricity storage of different durations; short (e.g., flywheels), medium (e.g., Li-ion batteries, or long (e.g., pumped hydro). Following the findings from a study by TERI (Spencer et al., 2020), we include a battery storage³ technology of 60 GW (120 GWh) in the model. The battery technology is assumed to work in tandem with solar PV technologies. We assessed whether the battery technology was a part of the 'least cost' optimal solution and, if so, whether or not it substituted the need for the GUI. The storage duration of the battery is assumed to be 4 hours. The hourly generation results in India for 2050 from the model run are shown in **Figure 9**.

³ Our focus in this study was to consider an alternative to the GUI that could help maximise the share of demand in India met by solar PV generation. We therefore consider battery storage located at the sites of solar PV generation in India. While hydro generation from neighbours Nepal and Bhutan, as well as pumped hydro storage within India are key to India's overall power system. However, they would not necessarily be tied to solar PV generation and therefore not considered a clear alternative to the GUI in this regard.



443 **Figure 9. Hourly power generation for India in 2050 - monthly average**

444 The model results show that (i) the battery technology is installed to its maximum
 445 capacity of 60 GW and (ii) that it does not substitute the installation of the GUI.
 446 Instead, both the interconnector and solar PV+Battery technologies work in tandem to
 447 meet the peak load demand India. With a battery technology, the peak load demand
 448 between 19:00 and 21:00 can be met by stored electricity from solar power
 449 generation earlier in the day.

450 **Financial Feasibility**


451 The net-present-value (NPV) of the proposed interconnector project is shown in **Figure**
 452 **11**. For almost all scenarios, the project NPV is negative. The strongest relationship is
 453 between NPV and interconnector (IC) unit cost. NPV decreases with increase in
 454 interconnector unit costs. The social discount rate also shows some relationships with
 455 the NPV of the interconnector. This could be because, at lower social discount rates, the
 456 penetration of renewables is higher, which increases the arbitrage opportunities across
 457 the interconnector.

458 Care must be taken when interpreting these results. The financial model builds on the
 459 projections of the technoeconomic model, relying on the technoeconomic model's
 460 determination of installed capacity, installation date, trade volume, and marginal price
 461 difference. So, while the revenue side of the interconnector's cashflow is similar between
 462 the technoeconomic model and financial model, and while both models use the same
 463 discount rate, the financial model also includes additional costs such as debt interest
 464 during construction and financing fees. Critically, the technoeconomic model is
 465 constrained such that the interconnector covers its costs, not that it is a profitable
 466 investment. It is fully expected that the financial model shows a less optimistic case for
 467 the interconnector given the same scenario.

468 As the technoeconomic model seeks to minimise total system costs, it will not
 469 necessarily choose capacities which allow for maximum profitability of the
 470 interconnector. As shown, in almost all scenarios, the maximum size available is chosen
 471 for the interconnector. This suggests that the presence of the interconnector
 472 substantially reduces total system costs, but the negative NPV shows that the
 473 interconnector itself is currently capturing these benefits. In almost all scenarios, the
 474 project IRR and equity IRR are positive, see Figure [REF]. If more of the benefit provided
 475 by the interconnector would be accrued by the interconnector itself (i.e., if its revenue
 476 were increased), or, if it was able to secure concessional and government financing and
 477 grants which lowered its costs of capital sufficiently, then the interconnector would be
 478 investible as-is.


479 In order to be aligned with the technoeconomic model, the interconnector revenue is
 480 calculated using a time-of-use tariff based on the difference in marginal costs between
 481 the connection nodes on either side of the interconnector. This means that as the

482 interconnector grows in capacity, this marginal difference becomes smaller and the
 483 interconnector’s revenue stream becomes smaller. If the interconnector were more
 484 constrained in size, the arbitrage opportunity might not be cannibalised. It is expected
 485 that the investment case for a smaller interconnector would be more favourable.



486 **Figure 10:** Relationship between Project and Equity mIRR and NPV
 487

488



489 **Figure 11:** Project net present value dependence on scenario parameters
 490

491 **Risk Sensitivity**

492 Project investibility is tested for sensitivity against a number of risks, as presented in
 493 Table 4. These risks reduce to proxies effecting the interconnector’s cashflow: CAPEX

494 overruns, OPEX overruns, and revenue impairment. Each scenario's sensitivity to these
495 risks is shown in Figure 13.

496 Scenario NPV is predictably affected by each of CAPEX, OPEX, and revenue. Increases
497 in revenue and reductions in CAPEX are able to make some scenarios NPV-positive, and
498 the opposite is also true. The observed effect of OPEX interdiction is considerably smaller
499 than that of CAPEX and revenue. The overall findings however, are robust to the risks
500 highlighted here.

501 Conclusions

502 The techno-economic case for a GCC-India interconnector is clear: an interconnector is
503 part of the least-cost 'optimal' power system in 64 of the 75 scenarios studied. Bi-
504 directional trade between the two regions can contribute towards reducing costs and
505 emissions across a range of scenarios. The trend of electricity flows gradually shifts from
506 the India->GCC direction in 2030 to the other way around by 2050. The overall trade
507 volumes are influenced by the location of the solar PV farm; locations further to the west
508 contribute towards higher trade volumes in the GCC->India direction. Of the cost
509 variables considered in the study the overall (social) discount rate is most strongly
510 correlated with the interconnector trade volumes. As the discount rate increases,
511 renewable power generation technologies are considered less techno-economically
512 favourable. This in turn leads to higher electricity flows in the GCC->India direction.
513 Finally, the role of storage was found to complement rather than substitute the GUI,
514 with both combining to towards meeting India's peak load.

515 The financial case for the CCG-India interconnector is less clear. Of the projections
516 developed for the scenarios from the technoeconomic model, only a small number are
517 immediately investible. However, the non-investible scenarios show a shortfall in
518 investment attractiveness consistent with the difference between the technoeconomic
519 models and financial models. Better harmonisation of the technoeconomic and financial
520 models will clarify the conditions for investibility of the interconnector. It is also expected
521 that a smaller interconnector will be a more attractive investment opportunity, for a
522 trade-off in total system cost reductions.

523 This study aimed to identify whether a combined techno-economic and financial case
524 exists for an interconnector between India and the GCC across a broad range of
525 scenarios. There are however additional aspects to consider – that were outside the
526 scope of the current study – in order to provide a more comprehensive picture. These
527 include energy efficiency measures in India, evolving demand patterns, coal with CCS,
528 and expanded trade with South-East Asia. Further, the study can be aligned more closely
529 with state and national policies in relation to power procurement strategies, wheeling
530 charges, grid integration, and financing options.

531 The starting point of this analysis was that GCC-India interconnector would result in
532 desirable outcome of increasing the share of India's electricity demand met by solar PV
533 generation. This was confirmed by the techno-economic model. However, two other
534 aspects from the modelling results were somewhat surprising and warrant further
535 analysis: 1. Significant electricity flows in the India->GCC direction; and 2. Unfavourable
536 financial case for the GUI. Both these aspects are sensitive to factors such as cost of
537 capital, electricity subsidies etc. One avenue for further exploration is to identify
538 policy/market conditions to encourage such 'system-optimal' investments that are risky
539 from an investor's perspective. Further, expanding the geographic scope could also alter
540 the overall feasibility of the GUI. For instance, the GCC is well-positioned to act as an
541 electricity trading hub between South-east Asia, India, and the African power pools. This
542 study provides an initial analysis of the GUI. However, further analysis of the aspects
543 described above would help provide a more comprehensive picture.

544 Author contributions

545 Conceptualization, M.H. and A.H.; Methodology, M.H., A.H., A.S., and L.K.; Software,
546 W.U.; Validation, A.S., M.W, L.K., and S.S.; Formal analysis, X.X.; investigation, X.X.;
547 resources, X.X.; data curation, X.X.; writing—original draft preparation, A.S., L.K., S.S.,
548 .; writing—review and editing, X.X.; visualization, X.X.; supervision, X.X.; project
549 administration, X.X.; funding acquisition, Y.Y. All authors have read and agreed to the
550 published version of the manuscript.

551 Funding

552 This study was funded by Oxford Policy Management's EEG programme and the UK
553 FCDO's Climate Compatible Growth Project.

554 Acknowledgements

555 The authors would like to thank Climate Parliament, IRADE, and Eric Williams (KAPSARC)
556 for their feedback.

557 Disclaimer

558 The views expressed in this report are the authors' and do not necessarily reflect the UK
559 government's official policies.

560 References

- 561 Asia Development Bank 2021. Lending Policies and Rates. [https://www.adb.org/what-](https://www.adb.org/what-we-do/public-sector-financing/lending-policies-rates)
562 [we-do/public-sector-financing/lending-policies-rates](https://www.adb.org/what-we-do/public-sector-financing/lending-policies-rates)
- 563 Bankrate.com 2021. 6-month Libor. [https://www.bankrate.com/rates/interest-rates/6-](https://www.bankrate.com/rates/interest-rates/6-month-libor.aspx)
564 [month-libor.aspx](https://www.bankrate.com/rates/interest-rates/6-month-libor.aspx).
- 565 Countryeconomy.com 2021. India – 10-Year Government Bond Yield.
566 <https://countryeconomy.com/bonds/india>
- 567 Flament, A., Joseph, P., Gerdes, G., Rehfeldt, L., Behrens, A., Dimitrova, A., Genoese,
568 F., Gajic, I., Jafar, M., Tidemand, N., Yang, Y., Jansen, J., Nieuwenhout, F., Veum,
569 K., Konstantelos, I., Pudjianto, D., Strbac, G. 2014. North Sea Grid: Annexes to
570 the Final Report. Imperial College London Consultants, ECN, WindGuard, CEPS,
571 DNV GL.
572 http://www.northseagrid.info/sites/default/files/NorthSeaGrid_Final_Report.pdf
- 573 Brinkerink, M., Gallachóir, B.Ó., Deane, P., 2019. A comprehensive review on the
574 benefits and challenges of global power grids and intercontinental interconnectors.
575 *Renew. Sustain. Energy Rev.* 107, 274–287.
576 <https://doi.org/10.1016/j.rser.2019.03.003>
- 577 Fatih Birol, 2021. Net zero by 2050 plan for energy sector is coming – Analysis [WWW
578 Document]. IEA. URL [https://www.iea.org/commentaries/net-zero-by-2050-plan-](https://www.iea.org/commentaries/net-zero-by-2050-plan-for-energy-sector-is-coming)
579 [for-energy-sector-is-coming](https://www.iea.org/commentaries/net-zero-by-2050-plan-for-energy-sector-is-coming) (accessed 4.7.21).
- 580 García-Gusano, D., Espegren, K., Lind, A., Kirkengen, M., 2016. The role of the discount
581 rates in energy systems optimisation models. *Renew. Sustain. Energy Rev.* 59, 56–
582 72. <https://doi.org/10.1016/j.rser.2015.12.359>
- 583 Howells, M., Rogner, H., Strachan, N., Heaps, C., Huntington, H., Kypreos, S., Hughes,
584 A., Silveira, S., DeCarolis, J., Bazillian, M., Roehrl, A., 2011. OSeMOSYS: The Open
585 Source Energy Modeling System. *Energy Policy* 39, 5850–5870.
586 <https://doi.org/10.1016/j.enpol.2011.06.033>
- 587 Kingdom of Saudi Arabia, 2015. The Intended Nationally Determined Contribution of the
588 Kingdom of Saudi Arabia under the UNFCCC, UNFCCC. UNFCCC.
- 589 REN21, 2020. Renewables 2020 Global Status Report. REN21.
- 590 Rose, A., Chernyakhovskiy, I., Palchak, J., Koebrich, S., Joshi, M., 2020. Least-Cost
591 Pathways for India's Electric Power Sector (No. NREL/TP-6A20-76153, 1659816,
592 MainId:6155). <https://doi.org/10.2172/1659816>
- 593 Spencer, T., Rodrigues, N., Pachouri, R., Thakre, S., Renjith, G., 2020. Renewable Power
594 Pathways: Modelling the Integration of Wind and Solar by 2030 in India. TERI.
- 595 The Government of the United Kingdom, 2020. Energy white paper: Powering our net
596 zero future [WWW Document]. GOV.UK. URL
597 [https://www.gov.uk/government/publications/energy-white-paper-powering-our-](https://www.gov.uk/government/publications/energy-white-paper-powering-our-net-zero-future/energy-white-paper-powering-our-net-zero-future-accessible-html-version)
598 [net-zero-future/energy-white-paper-powering-our-net-zero-future-accessible-](https://www.gov.uk/government/publications/energy-white-paper-powering-our-net-zero-future/energy-white-paper-powering-our-net-zero-future-accessible-html-version)
599 [html-version](https://www.gov.uk/government/publications/energy-white-paper-powering-our-net-zero-future/energy-white-paper-powering-our-net-zero-future-accessible-html-version) (accessed 4.7.21).
- 600 United Arab Emirates, 2020. Second Nationally Determined Contribution of the United
601 Arab Emirates.

- 602 Varro, L., Fengquan, A., 2020. China's net-zero ambitions: the next Five-Year Plan will
603 be critical for an accelerated energy transition – Analysis [WWW Document]. IEA.
604 URL [https://www.iea.org/commentaries/china-s-net-zero-ambitions-the-next-five-](https://www.iea.org/commentaries/china-s-net-zero-ambitions-the-next-five-year-plan-will-be-critical-for-an-accelerated-energy-transition)
605 [year-plan-will-be-critical-for-an-accelerated-energy-transition](https://www.iea.org/commentaries/china-s-net-zero-ambitions-the-next-five-year-plan-will-be-critical-for-an-accelerated-energy-transition) (accessed 4.7.21).
- 606 Meier, P. 2020. Guidebook for Economic and Financial analysis of Regional Electricity
607 Projects. World Bank Group. Washington, DC.
608 [https://openknowledge.worldbank.org/bitstream/handle/10986/34158/Guidebook](https://openknowledge.worldbank.org/bitstream/handle/10986/34158/Guidebook-For-Economic-and-Financial-Analysis-of-Regional-Electricity-Projects-A-Report-of-the-Pan-Arab-Regional-Energy-Trade-Initiative.pdf?sequence=4&isAllowed=y)
609 [-For-Economic-and-Financial-Analysis-of-Regional-Electricity-Projects-A-Report-](https://openknowledge.worldbank.org/bitstream/handle/10986/34158/Guidebook-For-Economic-and-Financial-Analysis-of-Regional-Electricity-Projects-A-Report-of-the-Pan-Arab-Regional-Energy-Trade-Initiative.pdf?sequence=4&isAllowed=y)
610 [of-the-Pan-Arab-Regional-Energy-Trade-Initiative.pdf?sequence=4&isAllowed=y](https://openknowledge.worldbank.org/bitstream/handle/10986/34158/Guidebook-For-Economic-and-Financial-Analysis-of-Regional-Electricity-Projects-A-Report-of-the-Pan-Arab-Regional-Energy-Trade-Initiative.pdf?sequence=4&isAllowed=y)
- 611 SARI/EI/IRADE Team, 2019. Case studies on financing models for cross-border
612 transmission lines. Presented at Workshop on 'Enhancing Energy Cooperation
613 between India-Nepal', 24th July 2019. [https://sari-energy.org/wp-](https://sari-energy.org/wp-content/uploads/2019/07/Session-3-Case-Studies-on-Financing-Models.pdf)
614 [content/uploads/2019/07/Session-3-Case-Studies-on-Financing-Models.pdf](https://sari-energy.org/wp-content/uploads/2019/07/Session-3-Case-Studies-on-Financing-Models.pdf)
- 615 PowerLinks Transmission Ltd (2009) 8th Annual Report 2008-09.
616 <https://www.powerlinks.co.in/pdf/tariff/bs89.pdf>
- 617 RBSA Advisors 2020. Cost of Capital in India, 4th Edition.
618 [https://rbsa.in/archives_of_research_reports/RBSA-Advisors-Cost-of-Capital-in-](https://rbsa.in/archives_of_research_reports/RBSA-Advisors-Cost-of-Capital-in-India-4th-Edition-December2020.pdf)
619 [India-4th-Edition-December2020.pdf](https://rbsa.in/archives_of_research_reports/RBSA-Advisors-Cost-of-Capital-in-India-4th-Edition-December2020.pdf)
- 620 The World Bank 2021. IBRD Financial Products, Lending Rates & Fees.
621 [https://treasury.worldbank.org/en/about/unit/treasury/ibrd-financial-](https://treasury.worldbank.org/en/about/unit/treasury/ibrd-financial-products/lending-rates-and-fees)
622 [products/lending-rates-and-fees](https://treasury.worldbank.org/en/about/unit/treasury/ibrd-financial-products/lending-rates-and-fees)

623 Appendices

624 Appendix A: Model structure

625 A linear optimisation model of a combined India-GCC power system was developed using
626 OSeMOSYS, an **open-source** energy system modelling tool. The model scope was as
627 follows:

628 Geographic scope (14 regions):

629 Bahrain, Kuwait, Oman, Qatar, Saudi Arabia (4 regions), UAE

630 India (5 regions)


631 Powerplant technologies (14 types): Coal, Natural Gas, Oil, Diesel, Waste, Biomass,
632 Hydro, Geothermal, Wind, Solar photovoltaics, Concentrating Solar Power, Wind, Wave,
633 and Nuclear

634 Time resolution (96 representative 'time slices'): 24 hours, 4 seasons

635 Model horizon: 2015-2050

636 A simplified structure of the model is shown below.

637 **Figure 12. Simplified model structure**



638

639 **Appendix B: Scenario table**


640 **Table 5.** Summary of twenty-five 'samples' covering the ranges of cost variables

Sample	CapitalCost	DiscountRate	DiscountRateIdv	FixedCostPercent
0	507	5.78%	5.07%	1.5%
1	1703	7.78%	6.03%	1.7%
2	1548	6.13%	9.12%	1.6%
3	1396	8.87%	8.04%	2.0%
4	921	5.30%	7.64%	1.6%
5	1445	5.85%	6.57%	1.8%
6	1573	8.61%	9.23%	1.5%
7	1301	8.22%	7.00%	1.3%
8	1981	6.84%	7.57%	1.4%
9	963	9.25%	6.94%	1.4%
10	1043	9.57%	9.89%	1.5%
11	565	8.44%	9.46%	1.6%
12	1192	5.41%	8.26%	1.9%
13	801	7.19%	5.72%	1.9%
14	602	8.18%	5.39%	1.7%
15	1655	6.50%	8.50%	1.3%
16	1911	7.36%	6.72%	1.8%
17	1808	9.08%	6.21%	1.2%
18	642	9.67%	9.67%	1.3%
19	1094	6.26%	5.83%	2.0%
20	1333	5.02%	5.55%	1.3%
21	1247	9.86%	8.86%	2.0%
22	863	7.92%	7.39%	2.1%
23	1843	6.71%	8.69%	2.0%
24	721	7.59%	7.84%	1.8%

641

642

Appendix C: Risk Sensitivity



643
644

Figure 13: NPV impairment due to interdiction of CAPEX, OPEX, and revenue